

Government of Jammu and Kashmir  
Civil Sectt; Forest Department

\*\*\*\*\*

Subject:- Laying of 220 KV Double Circuit  
transmission line from Kishenpur to  
Pampore.

Reference:- Administrative Council Decision No: 6  
dated: 28-1-1993.

Government Order No: 15-FST OF 1993  
Dated: 29-1-1993

....

Sanction is accorded to the laying of  
220 KV Double Circuit Transmission line from Kishenpur  
to Pampore by the Power Development Department passing  
through the Forest areas of Jammu, Udhampur, Batote,  
Ramban and Anantnag Forest Divisions involving a forest

118 Hectares on the following terms and conditions:-

- i. The legal status of the forest land will remain unchanged.
- ii. The maximum width permitted or the right of way will be 35 Mt.
- iii. The tree growth clearance over 3 meter wide strip below each conductor is permitted only for taking the tension stringing equipment but after the stringing work is completed, the natural regeneration will be allowed to come up over the cleared strip.
- iv. Within the right of way with the permission of the Forest Officers trees will be felled or lopped to provide 4.6 Mt minimum clearance from the conductors to prevent electric hazards.
- v. In case of transmission line, involves some hilly areas where such clearance from the conductor is already available trees will not be cut.
- vi. A firewood Depot will be opened to supply Firewood to the labourers working in the site execution of the line and no damage will be done to the adjoining forests.
- ii. Compensatory plantation to be raised over 236 Ha degraded forests at the cost of the project which comes to Rs.138.67 lacs.

By order of the Government of Jammu and Kashmir.

*[Signature]*  
Deputy Secretary to Government,  
Forest Department.

29/1/93